



Ref. Certif. No.

HU-003944

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product	Low-voltage Fuses for PV system
Name and address of the applicant	SUNTREE Electric Group Co., Ltd. Xinguang Industrial Zone, Liushi Town, Yueqing City, Zhejiang, P.R. China
Name and address of the manufacturer	SUNTREE Electric Group Co., Ltd. Xinguang Industrial Zone, Liushi Town, Yueqing City, Zhejiang, P.R. China
Name and address of the factory	SUNTREE Electric Group Co., Ltd. Xinguang Industrial Zone, Liushi Town, Yueqing City, Zhejiang, P.R. China
Ratings and principal characteristics	Rated voltage: 1000V DC; Rated current: 6A, 8A, 10A, 12A, 15A, 16A, 20A, 25A, 30A, 32A Rated breaking capacity: 20kA; gPV; Size: 10×38
Trademark (if any)	Suntree (logo)
Customer's Testing Facility (CTF) Stage used	N/A
Model / Type Ref.	SRF-30 ; CHF-30
Additional information (if necessary may also be reported on page 2)	Detailed information refer to test report CN22K1QV 001
A sample of the product was tested and found to be in conformity with	IEC 60269-6:2010 IEC 60269-1:2006+A1+A2
As shown in the Test Report Ref. No. which forms part of this Certificate	CN22K1QV 001

This CB Test Certificate is issued by the National Certification Body



TÜV Rheinland InterCert Kft., MEEI Division
H-1143 Budapest, Gizella út 51-57., Hungary
Web: www.tuv.com

Date: 2022-05-26

Signature: Wencai Zhang