

Zertifikat

Certificate



Zertifikat Nr. *Certificate No.*
R 50436940

Blatt *Sheet*
0001

Ihr Zeichen *Client Reference*
Q.X.Y.

Unser Zeichen *Our Reference*
01-SSC-50161652 004

Ausstellungsdatum
24.07.2019

Date of Issue
(day/mo/yr)

Genehmigungsinhaber *License Holder*

Suntree Electric Group Co., Ltd.
Xinguang Industrial Zone,
Liushi Town, Yueqing City,
Zhejiang Province 325604
P. R. China

Fertigungsstätte *Manufacturing Plant*

030-0000621822

Prüfzeichen *Test Mark*



Geprüft nach *Tested acc. to*

EN 60269-6:2011

EN 60269-1:2007+A1+A2

**Zertifiziertes Produkt (Geräteidentifikation)
*Certified Product (Product Identification)***

**Lizenzentgelte - Einheit
*License Fee - Unit***

Fuse Link (Low-voltage Fuse for PV System)

Fuse-link

Type Designation : SRF-30; CHF-30

5

Rated Voltage : DC 1000V

Rated Current : 1A; 2A; 3A; 4A; 5A; 6A; 8A; 10A; 12A; 15A;
16A; 20A; 25A; 30A and 32A

Rated Breaking Capacity: 20kA

Breaking Range : gPV

Rated Power Dissipation: no more than 2,5W at 0,7In
no more than 4,5W at In

Size : 10mm*38mm

Arc Voltage Limits : 3500V

5

Dem Zertifikat liegt unsere Prüf- und Zertifizierungsordnung zugrunde und es bestätigt die Konformität des Produktes mit den oben genannten Standards und Prüfgrundlagen. Zusätzliche Anforderungen in Ländern, in denen das Produkt in Verkehr gebracht werden soll, müssen zusätzlich betrachtet werden. Die Herstellung des zertifizierten Produktes wird überwacht.
This certificate is based on our Testing and Certification Regulation and states the conformity of the product with the standards and testing requirements as indicated above. Any additional requirements in countries where the product is going to be marketed have to be considered additionally. The manufacturing of the certified product is subject to surveillance.

TÜV Rheinland LGA Products GmbH, Tillystraße 2, 90431 Nürnberg

Tel.: +49 221 806-1371 e-mail: cert-validity@de.tuv.com
Fax: +49 221 806-3935 http://www.tuv.com/safety

